



City of Pembroke Pines Fire Rescue
Fire Prevention Bureau
 601 City Center Way 3rd FL
 Pembroke Pines, FL 33025
 PH (954) 499-9560



FIRE SAFETY INSPECTION REPORT

| | | | |
|-------------------------|----------------------|---------------------------|----------------------|
| Occupant Name: | Heron Pond | Inspection Date: | 6/14/2023 |
| Address: | 292 Southwest 83 Way | Inspected By: | Victor Santos |
| Suite: | Bldg. - #5 | Property Use Type: | Multifamily dwelling |
| Occupant Number: | | InspectionType: | Work without Permits |
| Occ. Sq. Ft.: | 20000 | Number of AEDs: | 0 |

| Insp. Result | Location | Code Set | Code |
|--------------|----------|----------|------|
|--------------|----------|----------|------|

| | | |
|-------------------|-----------------------------------|--|
| Deficiency | FL NFPA 01 2018 ADMINISTRATION | 1.7.12.1 - Work W/O Permits COPP Sec. 155.388 (see photo 1.1, 1.2) |
|-------------------|-----------------------------------|--|

Inspector Comments: Work has been conducted without permits that is concealing structural damage and without permission from the city's building department. Authorization for work will need to obtain through the appropriate permitting and application process. Work includes plywood, stucco, and paint in areas previously noted to have compromised structural members. All current and future covering of these areas must stop until an approved method is conducted through the previously mentioned approval process.

The AHJ shall have the authority to require plans and specifications to ensure compliance with applicable codes and standards.

| | | |
|-------------------|---|-------------------------------|
| Deficiency | FL NFPA 01 2018 OWNER RESPONSIBILITY | 10.2.1 - Owner Responsibility |
|-------------------|---|-------------------------------|

Inspector Comments: ****The owner, operator, or occupant shall be responsible for compliance with Florida Life Safety Code.****

ALL VIOLATIONS MUST BE ABATED IMMEDIATELY

Any and all violations must be corrected prior to the noted re-inspection date. Failure to remedy said deficiencies on or before the re-inspection date will result in a re-inspection fee and may also subject you to further action by the Fire Marshal's office.

The Inspector will return on or after **7/14/2023**.

MISSION STATEMENT

"The Pembroke Pines Fire Department is dedicated to the preservation of life, property and the environment. Our goal is to provide quality, cost effective professional services predicated upon the knowledge, skills, and abilities of our members."

Inspector:

SIGNATURE - COPIED SIGNATURE
COPIED SIGNATURE - COPIED SI
ED SIGNATURE - COPIED SIGNATU
PIED SIGNATURE - COPIED
PIED SIGNATURE - COPIED SI
PIED SIGNATURE - COPIED SI
PIED SIGNATURE - COPIED SI
PIED SIGNATURE - COPIED SI
Signature valid only in mobile-eyes documents

Victor Santos
6/14/2023

1.1 - 1.7.12.1.



1.2 - 1.7.12.1.



Ref: 72360