



**SECTION 1524 (FLORIDA BUILDING CODE)**  
**HIGH VELOCITY HURRICANE ZONES – REQUIRED OWNERS**  
**NOTIFICATION FOR ROOFING CONSIDERATIONS**

**1524.1 Scope:** As it pertains to this section, it is the responsibility of the roofing contractor to provide the owner with the required roofing permit, and to explain to the owner the content of this section. The provisions of Chapter 15 of the Florida Building Code, Building govern the minimum requirements and standards of the industry for roofing system installations. Additionally, the following items should be addressed as part of the agreement between the owner and the contractor. The owner's initial in the designated space indicates that the item was explained.

1. \_\_\_\_\_ **Aesthetics-Workmanship:** The workmanship provisions of Chapter 15 (High Velocity Hurricane Zone) are for the purpose of providing that the roofing system meets the wind resistance and water intrusion performance standards. Aesthetics (appearance) are not a consideration with respect to workmanship provisions. Aesthetic issues such as color or architectural appearance, that are not part of a zoning code, should be addressed as part of the agreement between the owner and the contractor.
2. \_\_\_\_\_ **Renailing Wood Decks:** When replacing roofing, the existing wood roof deck may have to be renailed in accordance with the current provisions of Chapter 16 (High Velocity Hurricane Zones) of the (Code) (the roof deck is usually concealed prior to removing the existing system).
3. \_\_\_\_\_ **Common Roofs:** Common roofs are those which have no visible delineation between neighboring units (i.e. townhouses, condominiums, etc.) In buildings with common roofs, the roofing contractor and/or owner should notify the occupants of adjacent units of roofing work performed.
4. \_\_\_\_\_ **Exposed Ceilings:** Exposed, open beam ceilings are where the underside of the roof decking can be viewed from below. The owner may wish to maintain the architectural appearance; therefore, roofing nail penetrations of the underside of the decking may not be acceptable. [The code] provides [an alternate for] maintaining its appearance.
5. \_\_\_\_\_ **Ponding Water:** The current roof system and/or deck of the building may not drain well and may cause water to pond (Accumulate) in low-lying areas of the roof. Ponding can be an indication of structural distress and may require review of a professional structural engineer. Ponding may shorten the life expectancy and performance of the new roofing system. Ponding conditions may not be evident until the original roofing system is removed. Ponding conditions should be corrected.
6. \_\_\_\_\_ **Overflow Scuppers (Wall Outlets):** It is required that rainwater flow off so that the roof is not overloaded from a buildup of water. Perimeter/edge walls or other roof extensions may block this discharge if overflow scuppers (Wall outlets) are not provided. It may be necessary to install overflow scuppers in accordance with the requirements of [Chapter 16].
7. \_\_\_\_\_ **Ventilation:** Most roof structures should have some ability to vent natural airflow through the interior of the structural assembly (the building itself). The existing amount of attic ventilation shall not be reduced; it may be beneficial to consider additional venting which can result in extending the service life of the roof.

\_\_\_\_\_  
Owner's/Agent Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Contractor's Signature

\_\_\_\_\_  
Date



Calvin, Giordano & Associates, Inc.  
EXCEPTIONAL SOLUTIONS

**SECTION 1525  
HIGH-VELOCITY HURRICANE ZONES—UNIFORM PERMIT APPLICATION**

*Florida Building Code 8th Edition (2023)*  
**High-Velocity Hurricane Zone Uniform Permit Application Form**

**INSTRUCTION PAGE**

**COMPLETE THE NECESSARY SECTIONS OF THE UNIFORM ROOFING PERMIT APPLICATION FORM AND ATTACH THE REQUIRED DOCUMENTS AS NOTED BELOW:**

| Roof System              | Required Sections of the Permit Application Form | Attachments Required<br>See List Below |
|--------------------------|--|--|
| Low Slope Application    | A,B,C  | 1,2,3,4,5,6,7                          |
| Prescriptive BUR-RAS 150 | A,B,C  | 4,5,6,7                                |
| Asphalt Shingles         | A,B,D  | 1,2,4,5,6,7                            |
| Concrete or Clay Tile    | A,B,D,E  | 1,2,3,4,5,6,7                          |
| Metal Roofs              | A,B,D  | 1,2,3,4,5,6,7                          |
| Wood Shingles and Shakes | A,B,D  | 1,2,4,5,6,7                            |
| Other                    | As Applicable                                    | 1,2,3,4,5,6,7                          |

**ATTACHMENTS REQUIRED:**

|    |   |
|----|---|
| 1. | Fire Directory Listing Page   |
| 2. | From Product Approval:<br>Front Page<br>Specific System Description<br>Specific System Limitations<br>General Limitations<br>Applicable Detail Drawings |
| 3. | Design Calculations per Chapter 16, or if applicable, RAS 127 or RAS 128  |
| 4. | Other Component of Product Approval   |
| 5. | Municipal Permit Application  |
| 6. | Owners Notification for Roofing Considerations (Reroofing Only)   |
| 7. | Any Required Roof Testing/Calculation Documentation   |

Florida Building Code 8th Edition (2023)  
High-Velocity Hurricane Zone Uniform Permit Application Form

Section A (General Information)

Master Permit No. \_\_\_\_\_ Process No. \_\_\_\_\_

Contractor's Name \_\_\_\_\_

Job Address \_\_\_\_\_

ROOF CATEGORY

- Low Slope
- Asphalt Shingles
- Mechanically Fastened Tile
- Metal Panel/Shingles
- Prescriptive BUR-RAS 150
- Mortar/Adhesive Set Tiles
- Wood Shingles/Shakes

ROOF TYPE


- New roof
- Repair
- Maintenance
- Reroofing
- Recovering

ROOF SYSTEM INFORMATION

Low Slope Roof Area (SF) \_\_\_\_\_ Steep Sloped Roof Area (SF) \_\_\_\_\_ Total (SF) \_\_\_\_\_

Section B (Roof Plan)

Sketch Roof Plan: Illustrate all levels and sections, roof drains, scuppers, overflow scuppers and overflow drains. Include dimensions of sections and levels, clearly identify dimensions of elevated pressure zones and location of parapets.



**Florida Building Code 8th Edition (2023)  
High-Velocity Hurricane Zone Uniform Permit Application Form**

**Section C (Low Slope Application)**

Fill in specific roof assembly components and identify manufacturer

(If a component is not used, identify as "NA")

System Manufacturer: \_\_\_\_\_

Product Approval No.: \_\_\_\_\_

Design Wind Pressures, From RAS 128 or Calculations:

Zone 1': \_\_\_\_\_ Zone 1: \_\_\_\_\_ Zone 2: \_\_\_\_\_ Zone 3: \_\_\_\_\_

Max. Design Pressure, from the specific product approval system: \_\_\_\_\_

Deck:  
Type: \_\_\_\_\_

Gauge/Thickness: \_\_\_\_\_

Slope: \_\_\_\_\_

Anchor/Base Sheet & No. of Ply(s): \_\_\_\_\_

Anchor/Base Sheet Fastener/Bonding Material:  
\_\_\_\_\_

Insulation Base Layer: \_\_\_\_\_

Base Insulation Size and Thickness: \_\_\_\_\_

Base Insulation Fastener/Bonding Material:  
\_\_\_\_\_

Top Insulation Layer: \_\_\_\_\_

Top Insulation Size and Thickness: \_\_\_\_\_

Top Insulation Fastener/Bonding Material:  
\_\_\_\_\_

Base Sheet(s) & No. of Ply(s): \_\_\_\_\_

Base Sheet Fastener/Bonding Material:  
\_\_\_\_\_

Ply Sheet(s) & No. of Ply(s): \_\_\_\_\_

Ply Sheet Fastener/Bonding Material:  
\_\_\_\_\_

Top Ply: \_\_\_\_\_

Top Ply Fastener/Bonding Material:  
\_\_\_\_\_

Surfacing: \_\_\_\_\_

Fastener Spacing for Anchor/Base Sheet Attachment:

Zone 1': \_\_\_\_\_" oc @ Lap, # Rows \_\_\_\_\_ @ \_\_\_\_\_" oc

Zone 1: \_\_\_\_\_" oc @ Lap, # Rows \_\_\_\_\_ @ \_\_\_\_\_" oc

Zone 2: \_\_\_\_\_" oc @ Lap, # Rows \_\_\_\_\_ @ \_\_\_\_\_" oc

Zone 3: \_\_\_\_\_" oc @ Lap, # Rows \_\_\_\_\_ @ \_\_\_\_\_" oc


Number of Fasteners Per Insulation Board: \_\_\_\_\_

Zone 1': \_\_\_\_\_ Zone 1: \_\_\_\_\_ Zone 2: \_\_\_\_\_ Zone 3: \_\_\_\_\_

Illustrate Components Noted and Details as Applicable:

Woodblocking, Gutter, Edge Termination, Stripping, Flashing, Continuous Cleat, Cant Strip, Base Flashing, Counterflashing, Coping, Etc.

Indicate: Mean Roof Height, Parapet Height, Height of Base Flashing, Component Material, Material Thickness, Fastener Type, Fastener Spacing or Submit Manufacturers Details that Comply with RAS 111 and Chapter 16.



**Florida Building Code 8th Edition (2023)  
High-Velocity Hurricane Zone Uniform Permit Application Form**

**Section D (Steep Sloped Roof System)**

Roof System Manufacturer: \_\_\_\_\_

Notice of Acceptance Number: \_\_\_\_\_

Minimum Design Wind Pressures, If Applicable (From RAS 127 or Calculations):  
Zone 1: \_\_\_\_\_ Zone 2: \_\_\_\_\_ Zone 3: \_\_\_\_\_

Roof Slope:  
\_\_\_\_\_: 12

Ridge Ventilation?  
\_\_\_\_\_

Mean Roof Height: \_\_\_\_\_

Deck Type: \_\_\_\_\_

Type Underlayment: \_\_\_\_\_

Insulation: \_\_\_\_\_

Fire Barrier: \_\_\_\_\_

Fastener Type & Spacing: \_\_\_\_\_

Adhesive Type: \_\_\_\_\_

Type Cap Sheet: \_\_\_\_\_

Roof Covering: \_\_\_\_\_

Type & Size Drip  
Edge: \_\_\_\_\_

**Florida Building Code 8th Edition (2023)  
High-Velocity Hurricane Zone Uniform Permit Application Form**

**Section E (Tile Calculations)**

For Moment-based tile systems, choose either Method 1 or 2. Compare the values for  $M_t$  with the values from  $M_r$ . If the  $M_t$  values are greater than or equal to the  $M_r$  values, for each area of the roof then the tile attachment method is acceptable.

Method 1 "Moment-Based Tile Calculations Per RAS 127"

(Zone 1:  $\text{___} \times \lambda \text{___} = \text{___}$ ) – Mg:  $\text{___} = M_{r1}$   $\text{___}$  Product Approval  $M_t$   $\text{___}$   
 (Zone 2:  $\text{___} \times \lambda \text{___} = \text{___}$ ) – Mg:  $\text{___} = M_{r2}$   $\text{___}$  Product Approval  $M_t$   $\text{___}$   
 (Zone 3:  $\text{___} \times \lambda \text{___} = \text{___}$ ) – Mg:  $\text{___} = M_{r3}$   $\text{___}$  Product Approval  $M_t$   $\text{___}$

Method 2 "Simplified Tile Calculations Per Table Below"

Required Moment of Resistance ( $M_r$ ) From Table Below  $\text{___}$  Product Approval  $M_t$   $\text{___}$

| M <sub>r</sub> required Moment Resistance* |       |       |       |       |       |
|--|-------|-------|-------|-------|-------|
| Mean Roof Height Roof Slope                | 15'   | 20'   | 25'   | 30'   | 40'   |
| 2:12                                       | -46   | -47.6 | -49.4 | -50.9 | -53.3 |
| 3:12                                       | -47.3 | -48.9 | -50.7 | -52.2 | -54.6 |
| 4:12                                       | -47.2 | -52.0 | -53.8 | -55.3 | -57.9 |
| 5:12                                       | -39.8 | -41.5 | -42.8 | -43.7 | -45.7 |
| 6:12                                       | -39.6 | -40.6 | -41.9 | -42.9 | -44.8 |
| 7:12                                       | -39.4 | -40.3 | -41.6 | -42.6 | -44.6 |

Method 2 may be utilized within Broward County Exposure C only.

For Uplift-based tile systems use Method 3. Compare the values for  $F'$  with the values for  $F_r$ . If the  $F'$  values are greater than or equal to the  $F_r$  values for each area of the roof then the tile attachment method is acceptable.

Method 3 "Uplift-Based Tile Calculations Per RAS 127"

(Zone 1:  $\text{___} \times L \text{___} = \text{___} \times w: = \text{___}$ ) – W:  $\text{___} \times \cos r \text{___} = F_{r1}$   $\text{___}$  Product Approval  $F'$   $\text{___}$   
 (Zone 2:  $\text{___} \times L \text{___} = \text{___} \times w: = \text{___}$ ) – W:  $\text{___} \times \cos r \text{___} = F_{r2}$   $\text{___}$  Product Approval  $F'$   $\text{___}$   
 (Zone 3:  $\text{___} \times L \text{___} = \text{___} \times w: = \text{___}$ ) – W:  $\text{___} \times \cos r \text{___} = F_{r3}$   $\text{___}$  Product Approval  $F'$   $\text{___}$

| Where to Obtain Information  |                      |   |
|--|----------------------|---|
| Description  | Symbol               | Where to find   |
| Design Pressure  | Zones 1, 2, 3        | From applicable table in RAS 127 or by an engineering analysis prepared by PE based on ASCE 7 |
| Mean Roof Height   | H                    | Job Site  |
| Roof Slope   | $\theta$             | Job Site  |
| Aerodynamic Multiplier   | $\lambda$            | Product Approval  |
| Restoring Moment due to Gravity  | $M_g$                | Product Approval  |
| Attachment Resistance  | $M_t$                | Product Approval  |
| Required Moment Resistance   | $M_r$                | Calculated  |
| Minimum Attachment Resistance  | $F'$                 | Product Approval  |
| Required Uplift Resistance   | $F_r$                | Calculated  |
| Average Tile Weight  | W                    | Product Approval  |
| Tile Dimensions  | L = length W = width | Product Approval  |
| All calculations must be submitted to the building official at the time of permit application. |                      |   |